

ISO 15848-1 QUALIFICATION CERTIFICATE



Industrie Service

Certificate No.: 278927

Ref. Test report No.: 278926

We hereby certify that the valve below has passed the fugitive emission test successfully according to Class BH of ISO15848-1:2015+Amd.1:2017 for a total of 1500 cycles.

Name of manufacturer	Suzhou FLEU Valve Co., Ltd.
Address of manufacturer	No.767, Huagang Road, Wujiang Economic Development Area, PC:215200, Suzhou City, Jiangsu Province, P.R. China
Item	DN80 PN40 Gate Valve
Valve size	DN80 (NPS3)
Pressure rating	PN40(Class300)
Stem size	Φ24 mm
Body/bonnet material	1.0619
Seal material	Graphite
Valve assembly drawing no.	135.032-11-80-00

The tested valve covers performance class (para.6.6):

ISO FE BH – CO₂ –SSA 0 –t(-29℃, 300℃) – PN40 – ISO 15848-1


Extension of qualification (in particular) to untested valves in accordance with paragraph 8 of ISO15848-1.

Other stem sizes qualified: 12 mm up to 48 mm

Other pressure ranges qualified: PN40 and lower

This certificate must be read in conjunction with test report No.:278926

Shanghai, July 13, 2021
(Place, date)


Guilin Chen
TÜV SÜD Industrie Service GmbH
 Westendstr. 199
 80686 München Germany



TÜV SÜD Industrie Service GmbH
Shanghai Office
Floor 3-13, No.151, Heng Tong Road,
Shanghai 200070 P. R. China

Tel.: +86 21 6141-0123
Fax: + 86 21 6140-8600